## Site checklist for use of H+H Calculated Ψ-values EW233

EW233: Brick + 100mm Cavity fully filled with insulation (0.032W/mK) + 100mm Celcon High or Super Strength Completed form to be returned to project SAP Assessor



Site details:					
External wall				Yes	No
Are the inner leaves built using 100mm Celcon Higher Strength blocks?					
Are the 100mm cavities insulated with 100mm (0.032W/mK) full fill insulation?					
Are the internal finishes plasterboard on dabs?  Note: H+H Calculated Ψ-values EW233 are only applicable if 'Yes' is answered to al	l of the above				
			Select one option	n	
Ground Floor	r	100mm	125mm	150mm	Other (state)
Floor insulation thickness (0.022W/mK conductivity) Ensure floor insulation is fitted tightly to blockwork with no gaps	Ĺ				
Floor construction				S	Select one option
Cavity wall insulation continues at least 215mm below top of beam  Minimum 65mm screed with 20mm of edge insulation with conductivity of 0.025W/mK (or equiv			ınd Celcon I	block infill	
Cavity wall insulation continues at least 215mm below underside of slab  150mm Cast in-situ suspended co					
Cavity wall insulation continues at least 215mm below underside of slab  100mm Groundbearing co					
				Other Yes	No
Have Celcon Foundation blocks have been used below groun	d?			100	
Note: H+H Calculated Ψ-values EW233-GF00, 01 and 02 are only applicable if Celcon Founda	tion blocks have beer	n used,			•
<u>Openings</u>				Yes	No
Do window/door frames overlap cavity by 30mm minimum?				165	NO
			Eurocell Cavalok (fully	Kingspan	Other
Cavity closers used			insulated)	Thermabate	
Note: H+H Calculated Ψ-values EW233-SL00, RV00 and LN00 are only applicable for these na	imed closers	(Not I	100HORCBX)		
Lintels used (Select one option)		(. 101 )	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		
Catnic Thermally Broken Lintel		•	nner and ou		
Keystone / IG Hi-therm+ Lintel Insulated open back lintel (max 3mm single linter) Insulated lintel (max 3mm steel) with continuous perforated base p					
Note: H+H Calculated Ψ-values EW233- LN00 are not applicable for Other lintel (types				Other	
Party walls (leave blank if not applicable)					
Select one of	ption				Select one option
2 x 100mm Celcon Standard 75mm Fully 2 x 100mm Celcon High/Super Strength 100mm Fully				led cavity	
2 x 100mm Aggregate Concrete 150mm Fully				-	
Roof	•			ne option	•
			400mm	500mm	Other (state)
Insulation quilt to horizontal ceilings Cavity wall insulation continues at least 200mm above top of roof insulation			150mm between	100mm between	150mm between
Insulation to sloping ceilings (leave blank if not applicable) minimum 50mm	(0.022W/mK) bene	eath rafters +	(0.044W/mK)	(0.022W/mK)	(0.022W/mK)
Intermediate floors			Select one option		Othor
Timber joists (leave blank if not applicable)	[	195mm	240mm	300mm	Other (state)
	L				
Concrete planks (Laure Marie Vierrande)			150mm	225mm	Other (state)
Concrete planks (leave blank if not applicable)					<u> </u>
Checklist completed by					
(print name) (job title)	(company nam	20)		(date)	