



Staifix HRT4 or other approved AD E Type A tie.

Full fill Party wall cavity insulation

10mm packing piece on joist ends

H+H UK limited Jumbo Blok (630x250x100) infill between joists

Factory installed web filler.

12.5mm Plasterboard on 10mm Dabs

Vertical Wall Panels. Compressive strength 4N/mm². Thermal conductivity - 0.17W/Mk

Continuous band of adhesive min 25mm from floor/wall junction.

Skirting to have continuous bead of sealant applied to rear and expanding foam tape applied to underside and mastic seal finish.

240mm joists

Plasterboard to u/s of floor joists

Continuous band of adhesive min 100mm from ceiling/wall junction.

12.5mm Plasterboard on 10mm Dabs

REV.	DATE.	DESCRIPTION.	BY.

These details have been produced for guidance only. It is the responsibility of the building designer to ensure that the details shown are compatible with the overall building design and will satisfy the relevant parts of the Building Regulations applicable before they are adopted into the project design.



H+H UK Limited
 Technical Services Dept.
 Celcon House
 Ightham, Sevenoaks
 Kent, TN15 9HZ.
 Tel +44 (0)1732 880580
 Email tsd@hhcelcon.co.uk

TITLE Vertical Wall Panel detail 240mm intermediate floor			
DWG No. VED046			
DRAWN BY MAB		CHECKED BY SJK	
DATE 13/7/21	SCALE 1:100	REV. NO. 00	

Junction of 240mm intermediate floor with separating wall